



TRANSPOWER



# FIRST ALERT

29 July 2015

Maximo #s 7300, 7845, 8598, 8998, 9398

## Mind the gate!

### EVENT



In May, June and July there were **five** occasions reported where gates at Transpower sites have been:

- left open
- not fully closed
- left unlocked and unattended, or
- locked when personnel were still on site.

Please note:

- road gates are to be locked when sites are unmanned
- when personnel are on site, road gates are to be closed but not locked (for emergency access/egress purposes).

### IMMEDIATE ACTIONS

- Actions have been taken in relation to the five incidents.
- Please refer to Transpower's specification – TP.SS.07.40, *Station security – procedures*.
- Remember to close gates after entry and lock gates when exiting . Unauthorised access to our sites is a major risk to public safety.
- Ensure open gates are fully attended or monitored.



For more information  
please contact:

Name: Peter Bartlett  
Transpower Health & Safety Manager  
027 809 8130  
[peter.bartlett@transpower.co.nz](mailto:peter.bartlett@transpower.co.nz)