



FIRST ALERT

Date 05 August 2014

Haywards Substation/Site Personnel Gate.

EVENT

At approximately 09:15 on Tuesday 5th August 2014, the personnel gate next to vehicle access gate A was found wedged open and unsupervised. The open access to the Haywards site represents a serious breach of site security.



A core requirement of Transpower's public safety requirements is to place a priority on ensuring that members of the public cannot be harmed through gaining access to our sites *without supervision*. This deliberate action of keeping this access point open had the potential to compromise public safety.

Staff are reminded that security at all Transpower sites must be maintained and all access points are secured to prevent unauthorised access.

IMMEDIATE ACTIONS

- Wedge removed and gate closed.
- Email sent to all Hayward's site managers, to remind all staff of this is unacceptable behaviour.



For more information
please contact:

Name: D.Kooyman
Designation: Safety & Health Practitioner
Ph: Mob: 0212283986
danny.kooyman@transpower.co.nz