



# *Safety Advice 16-2008 (NZ)*

---

## **Fatal Incident at Zone Substation**

On 21 October 2008 a member of the public, a 16 year old girl, received fatal burns and electric shock when she climbed a substantial security fence around a zone substation, entered the 33kV structure area, climbed a concrete structure pole and contacted a 33kV line.

October 2008