

Lost Time Injury – Connecting of Generators

Issue date	16 February 2018
Issued by	Vincent Cranny, Head of Health, Safety and Environment
Applicable to	All staff Authorised to connect generators

On 12 February 2018 an ENW Engineer was injured when a flashover occurred as he was opening the LV isolators following connection and synchronising of a generator.

The investigation into the incident is ongoing but all staff who are Authorised to connect generators are reminded that all Personal Protective Equipment must be worn as required when carrying out Operational activities.

