

DOCUMENTATION

ScottishPower *Express*

Reference no.: EXP-12-111

Document: Update to OPSAF-04-024

Date: 25/06/2018



Update to OPSAF-04-024 Issue 5. Identification, Register, Issue, Control & Inspection of HV Test Prods, HV Earthing Devices & Ancillary Equipment

[OPSAF-04-024](#) has recently received its periodic update to reflect the current business structure and clarify areas where queries have arisen.

The document now makes clear that 'Competent Users' may if necessary inspect and remove items from Quarantine and return to the store or take to site. This was previously permitted, however clarity of this point needed to be improved.

Persons who hold DE-1 are now classed as 'Competent Users' for the inspection and return of portable earthing devices to the store shelf.

Earthing Device control at Transmission sites is now accurately summarised, as are Test Prods permanently held on test vans.

The flow charts within the document have been clarified to assist with understanding of who may return equipment to either the Quarantine area, or available shelves within test prod stores.

The requirements for booking out and in Test Prods, Earthing Devices and Ancillary Equipment has not been changed.

Recommendations and action points

The updated version is available on the [EN Document Library](#).

SAPs and Authorised Persons involved in work with Test Prods, Earthing Devices and Ancillary Equipment should familiarise themselves with the revision.

