

TXUAUSTRALIA SAFETYGRAM

TXUAUSTRALIA
Michael Shone
Health & Safety Mgr
14 Floor, 452 Flinders St
Melbourne, 3000
Ph (03) 9679 4077
Fax (03) 9229 6297



ESAA
Secretariat
PO Box A2492
Sydney South NSW 2000
Telephone (02) 9233 7222
Facsimile (02) 9233 7244

ACN 052 416 083

ESAA 14/2003

DATE: 14/02/03	TXUAUSTRALIA SAFETYGRAM
DATE OF INCIDENT: 19/01/03	REPORTED BY: Dave Harden

Details of Incident:

Overhead line work party were required to upgrade a 300 Kva transformer to a 500 Kva. The distribution substation was constructed with a street circuit and dedicated subsidiary customer circuit. The upgrade included CT metering work which meant that on the day an REC was contracted to install LV buswork and CT meters were being installed.

At the end of the work the line work party restored the substation HV and then the LV

During restoration there was an REC working at the CT buswork chamber who received an electric shock

Extent of injury/damage:

Action taken:

Additional comments:

Severity of incident:

- FATAL:** Potential to have caused death
HIGH: Potential to have caused serious injury, permanent disability, ill health or serious damage to plant and equipment.
MEDIUM: Potential to have caused temporary disability or minor damage to plant and equipment.
LOW: Potential to have required minor First Aid.

FURTHER INFORMATION- CONTACT : Michael Shone 03 96794077 Mob.: 0417320582
michael.shone@txu.com.au