

HSE Alert Form



Alert Number: 2014.11

eSafe No	INC 1115380	Location	Yerra	Date	19 March 2014
-----------------	-------------	-----------------	-------	-------------	---------------

Description of Hazard/Incident *(What happened?)*

Corroded Single Wire Earth Return (SWER) 3/12 steel conductor broke during planned defect remediation work

Extent of Impact *(Details of injury, environmental harm, equipment damage, etc.)*

Nil injury

Key Facts *(What are the key facts ?)*

- Workcrew completed Daily/Task Risk Management Plan (DTRMP) for task of re-conductoring corroded SWER 3/12 steel conductor which was under HV Access conditions as part of planned defect remediation work. After untying the conductor the crew member placed it on a pole step ready for retrieval when the conductor broke and fell to ground in the established drop zone
- Workcrew assessed site and checked on all staff to ensure no injury had occurred
- Workcrew reported incident to Supervisor and completed the rest of the work



Note: Picture shows an example of the conductor – not the one that broke related to this incident

Actions *(Information on corrective actions implemented that may prevent harm and or assist others in preventing a similar occurrence)*

All Managers to ensure

Working on suspect 3/2.75 SCGZ (3/12 steel) conductor on overhead structures SP0231 [SWP](#) and [Field Instruction](#) is communicated and understood by work crews prior to undertaking this activity.

Contact for further Information

Name: Nick Grant	Position: A/AOM Wide Bay South
-------------------------	---------------------------------------

IMPORTANT NOTES:

This advice is provided in confidence for distribution to ENA members for information only. This advice has not been modified by ENA.

The issuing company must refer to the "Guidelines for the notification and distribution of ENA Significant Incident Advice" before issuing this Significant Incident Advice.

ENA members acknowledge and agree that they receive and treat the information provided in this SIA for information purposes only, and to release the member submitting the SIA from any claims arising from reliance on the SIA.