



SAFETY ALERT



Subject: Fire in Substation Incinerating Toilet

Date: 02/07/2019

Description: WEL Networks currently has incinerating toilets installed at a number of its substations. Significant smoke damage within a WEL Networks substation has been caused by a fire in one of these units. It would appear that the toilet had been used immediately prior to a worker departing the building on the same day. At this stage the actual cause of the fire is unknown.



Recommendations:

In the interim all existing incinerating toilets at WEL substations will be marked 'DO NOT USE' until we understand the issue and have determined a suitable course of action.

For further information contact: The WEL Networks Health & Safety Team.