## HAYWARDS SC3 & SC4 CARBON DIOXIDE (CO2) FIRE SUPRESSION ACTIVATION HUMAN ERROR INCIDENT (HEI)

## **EVENT**

Haywards Synchronous Condensers SC3 & SC4 have a common CO<sub>2</sub> fire suppression system which is activated by the Electrical Protection system in the event of certain faults.

The CO2 system was isolated at the commencement of the project. These isolations were to prevent a trip being sent to the fire system. During the precommissioning testing of the new SC4 protection system the Transfield Services Technician failed to ensure all electrical isolations of the  $CO_2$  system were correct for the testing to be undertaken.

The technician did not have all the information (tools) required to complete the task correctly or safely. The drawing which was being used referred to another document that was not available.

The technician then completed a visual inspection of the circuit and decided to remove the relay. The wiring was connected to a normally closed circuit with an external 24V supply. This removal of the relay resulted in the fire protection panel sending a signal to the  $CO_2$  system to activate, fortunately the system had been isolated preventing a gas dump into the condenser and the  $CO_2$  gas did not flood into the building.



HAY SC3 & SC4 CO₂ Fire Suppression System

## Learnings

If you don't have the correct information or tools to complete the task:

STOP - Step back and take five

**INVESTIGATE** – Find the correct information or tools, consider third party systems, if you can't find the information...ask someone.

**RESET** – Find the safest point to start the task again

**LEARN** – Put a system in place, revisit the design and educate others

ALWAYS USE OR HAVE THE CORRECT TOOLS FOR THE JOB

## **IMMEDIATE ACTIONS**

- CO<sub>2</sub> bottles purged and urgently refilled
- CO<sub>2</sub> system isolation design is to be reviewed
- Labels have been added to the SC3 & SC4 stating that the CO<sub>2</sub> fire suppression system shall be isolated at the Fire Protection Panel
- HEI report instigated





For more information please contact:

15 August 2014

Ben Bulling
HSCR Project Supervisor
Mob: 021 629 954
ben bulling@transpower.co.n

Transpower New Zealand Ltd The National Grid